

Certificate of Compliance

Certificate: 1408826

Master Contract: 186437

Project: 1408826

Date Issued: March 21, 2003

Issued to: SANUVOX TECHNOLOGIES INC.
5757 Cavendish, Suite 411
Montreal, QC H4W 2W8
CANADA

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Issued by:


G. Raymond, Eng.

Authorized by: Alain Ste-Marie
Operations Manager

PRODUCTS

CLASS 3453 01 - BACTERICIDAL LAMPS

CLASS 3453 81 - BACTERICIDAL LAMPS - CERTIFIED TO U. S. STANDARDS

Air Purifiers with UV light for installation into ducts, cord-connected or permanently connected, "Bio-Wall", rated 120Vac, 60Hz, 9A max.

APPLICABLE REQUIREMENTS

- | | | |
|---|---|--|
| CAN/CSA-C22.2 No. 177-92 (as reference) | - | Clock Operated Switches |
| UL 917 (as reference) | - | Clock-Operated Switches |
| CAN/CSA-C22.2 No. 74-92 | - | Equipment for Use with Electric Discharge Lamps |
| UL Std No. 1570 | - | Fluorescent Lighting Fixtures |
| TIL No I-34 | - | Additional requirements for Electrical and Electronic Equipment which contains Ultraviolet Radiation Sources |

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.



Supplement to Certificate of Compliance

Certificate: 1408826

Master Contract: 186437

Product Certification History

| Project | Date | Description |
|----------------|----------------|---|
| 1408826 | March 21, 2003 | Air Purifier, duct installed, Bio-Wall. |